

	GENERAL SPECIFICATIONS QUANTITY: ONE (1) MODEL: AGI-150 RL MAXIMUM FLOW RATE: 150 GPM STATIC CAPACITY: 202.5 GALLONS RETENTION TIME: 81 SEC TYPE: SINGLE WALL, ABOVE-GROUND MATERIAL: 10 GA 304 STAINLESS STEEL BUILT IN ACCORDANCE WITH U.L. 1D42
	<u>NOTES</u> STANDARD CONTROL PANEL OPERATES ON 208V–3ø + NEUTRAL SERVICE VOLTAGE – OPTIONAL PANELS AVAILABLE
	GEAR MOTOR RATED AT 0.44 FLA, 115V – 60 Hz
	IMMERSION HEATERS OPERATE AT 208V
	ALL ELECTRICAL AND PLUMBING CONNECTIONS ARE SUBJECT TO LOCAL CODES
	HIGHLAND TANK OFFERS A WIDE VARIETY OF OPTIONS AND CUSTOMIZATIONS TO ACCOMMODATE PROJECT CONDITIONS – CONTACT HIGHLAND TANK FOR MORE INFORMATION
NLET	RIGHT-TO-LEFT FLOW SHOWN LEFT-TO-RIGHT FLOW AVAILABLE
4	CUSTOMER APPROVAL
	THE CUSTOMER HAS REVIEWED THIS DRAWING AND VERIFIED THE ACCURACY OF ALL INFORMATION AND DIMENSIONS.
	SIGNED:
	DATE:
72″±	NITE: ALL RIGHTS RESERVED. THIS DRAWING, DR ANY PART THEREDF, MUST NOT BE REPRODUCED IN ANY FORM WITHOUT WRITTEN PERMISSION FROM HIGHLAND TANK, UNLESS OTHERVISE NOTED, HIGHLAND TANK SHALL RESPONSIDE DNLY FOR ITEMS INDICATED DI THIS FABRICATION DRAWING. THE CUSTOMER IS RESPONSIBLE FOR VERIFYING THE CORRECTNESS OF THE TYPE, SIZE, AND LOCATION OF ALL FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.
	Highland Tank®
	GreaseStopper®AUTOMATIC GREASE INTERCEPTOR AGI-150 RL
	CUSTOMER:
¥	PROJECT:
DIMENSION TOLERANCE: ± 1"	QUOTE NO.: SCALE: DATE: DVG. BY: DVG. ND: NTS 1/2/19 MGS AGI-150 RL
\cdot $\omega_{11} = 0 = 0 = 0 = 0 = 0 = 0 = 0 = 0 = 0 = $	