

	<u>GENERAL SPECIFICATIONS</u> QUANTITY: ONE (1) MODEL: MOI-20 MAXIMUM FLOW RATE: 20 GPM STATIC CAPACITY: 43.9 GALLONS TYPE: SINGLE WALL, UNDERGROUND MATERIAL: 10 GA CARBON STEEL CONTINUOUS WELD INTERIOR AND EXTERIOR SEAMS SURFACE PREP: SSPC-SP 10 BLAST ALL SURFACES INT. & EXT. COATING: CHEMLINE 2240 – 15 MILS DFT
	<u>NOTES</u> STANDARD TANK MATERIAL IS COATED CARBON STEEL – STAINLESS STEEL CONSTRUCTION IS OPTIONAL
	DRAWING SHOWS STANDARD TANK HEIGHT DIMENSION FROM INLET/OUTLET FITTINGS TO FINISHED FLOOR – CUSTOMER MUST SPECIFY HEIGHT DIMENSION MODIFICATIONS REQUIRED TO MEET PROJECT PLUMBING CONDITIONS
	STANDARD TANK LID IS RATED FOR PEDESTRIANS ONLY – H–20 TRAFFIC RATED LIDS ARE OPTIONAL
	INTEGRAL OIL STORAGE CHAMBERS AND HIGH LEVEL ALARMS ARE AVAILABLE AS OPTIONS
NPT VENT	
	CUSTOMER APPROVAL
<u></u> 5 <u></u> ¹ ¹	THE CUSTOMER HAS REVIEWED THIS DRAWING AND VERIFIED THE ACCURACY OF ALL INFORMATION AND DIMENSIONS.
	SIGNED:
	DATE:
	NDTE: ALL RIGHTS RESERVED. THIS DRAWING, DR ANY PART THEREDF, MUST NDT BE REPRDDUCED IN ANY FORM WITHDUT WRITTEN PERMISSION FROM HIGHLAND TANK. UNLESS DTHERWISE NDTED, HIGHLAND TANK SHALL BE RESPONSIBLE DNLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING. THE CUSTOMER IS RESPONSIBLE FOR VERIFYING THE CORRECTNESS OF THE TYPE, SIZE, AND LDCATION OF ALL FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.
	Highland Tank [®]
	manual oil interceptor $MOI-20$
	CUSTOMER:
	PROJECT: QUOTE NO.:
DIMENSION TOLERANCE: ± 1"	SCALE: DATE: DWG. BY: DWG. ND: $7/7/20$ MGS MGS $MOI - 20$