



GENERAL SPECIFICATIONS

QUANTITY: ONE (1)
MODEL: AGI-100 FM
MAXIMUM FLOW RATE: 100 GPM
STATIC CAPACITY: 103.9 GALLONS
GREASE HOLDING CAPACITY: 632 LBS
RETENTION TIME: 62.3 SEC
TYPE: SINGLE WALL, UNDERGROUND
MATERIAL: 10 GA 304 STAINLESS STEEL
BUILT IN ACCORDANCE WITH U.L. 1D42

NOTES

DRAWING SHOWS STANDARD TANK HEIGHT DIMENSION FROM INLET/OUTLET FITTINGS TO FINISHED FLOOR – CUSTOMER MUST SPECIFY HEIGHT DIMENSION MODIFICATIONS REQUIRED TO MEET PROJECT PLUMBING CONDITIONS

DIGITAL TIMER MUST BE PLUGGED INTO A DEDICATED 20 AMP GROUND FAULT CIRCUIT INTERRUPTER (GFCI) RECEPTACLE

GEAR MOTOR RATED AT 0.44 FLA, 115V – 60 Hz

IMMERSION HEATERS RATED AT 1,500W, 115V

ALL ELECTRICAL AND PLUMBING CONNECTIONS ARE SUBJECT TO LOCAL CODES

HIGHLAND TANK OFFERS A WIDE VARIETY OF OPTIONS AND CUSTOMIZATIONS TO ACCOMMODATE PROJECT CONDITIONS – CONTACT HIGHLAND TANK FOR MORE INFORMATION

CUSTOMER APPROVAL

THE CUSTOMER HAS REVIEWED THIS DRAWING AND VERIFIED THE ACCURACY OF ALL INFORMATION AND DIMENSIONS.

SIGNED: _____

DATE: _____

NOTE:

ALL RIGHTS RESERVED. THIS DRAWING, OR ANY PART THEREOF, MUST NOT BE REPRODUCED IN ANY FORM WITHOUT WRITTEN PERMISSION FROM HIGHLAND TANK. UNLESS OTHERWISE NOTED, HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING. THE CUSTOMER IS RESPONSIBLE FOR VERIFYING THE CORRECTNESS OF THE TYPE, SIZE, AND LOCATION OF ALL FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.

**Highland Tank®**

GreaseStopper® AUTOMATIC GREASE INTERCEPTOR

AGI-100 FM

CUSTOMER: _____

PROJECT: _____

QUOTE NO.: _____

ORDER: _____

SCALE: _____	DATE: 1/20/18	DWG. BY: MGS	DWG. NO.: _____
--------------	---------------	--------------	-----------------

DIMENSION TOLERANCE: ± 1" NTS 1/20/18 MGS AGI-100 FM