


NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANKE,
HIGHLAND TANKE SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
RABRICATION DRAWING OLIVESS OTHERWISE
NOTED. CUSTOMER TO SESPONSIBLE FOR
NOTED. CUSTOMER OF SESPONSIBLE FOR
LOCATION OF FITTINGS. ACCESSORIES. AND
COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS
REQUIRED BY INSTALLATION
CONTRACTOR. TOUCH UP PAINT SHIPPED
WITH TANK.







<u>DESIGN_DATA</u>							
CAPACITY - 120 GALLONS							
TYPE - DOUBLE WALL - TYPE I							
NO. REQ							
OPERATING PRESSURE - ATMOSPHERIC							
SPECIFIC GRAVITY = 1.0							
TANK MATERIAL - MILD CARBON STEEL							
THICKNESS - INNER- 12 GA THICKNESS - OUTER- 12 GA							
CONSTRUCTION — INNER — LAP WELD OUTSIDE ONLY OUTER — LAP WELD OUTSIDE ONLY							
TANK TEST - INNER - 2 PSIG OUTER- 2 PSIG AND FULL VACUUM							
INT. FINISH — NONE —							
EXT. FINISH - SHOP PRIMER -							
LABEL - UL 142							

<u>LEGEND</u>								
Α	2" FITTING							
В	4" FITTING (PRIMARY EMERGENCY VENT USE)							
С	4" FITTING MOUNTED IN INTERSTICE EXTENSION BOX — SECONDARY EMERGENCY VENT							
D	1/2" FITTING THROUGH OUTER SHELL ONLY WITH BUTTON SITE GLASS							
Ε	_							
F								

TANK MFG CO		ghl	<b>and</b>	<b>Tanl</b>	®	
120	GAL	DW	LUBE	TANK		
CUSTOMER:						
PROJEC <sup>-</sup>	Γ:					
OUDTE N	JП:		CHI	C'D BY:		

00120LDW

SCALE: DATE: 1" = 12"