



GENERAL SPECIFICATIONS

QUANTITY: DNE (1)
MDDEL: EDI-150
MAXIMUM FLDW RATE: 150 GPM
STATIC CAPACITY: 188.4 GALLONS
TYPE: SINGLE WALL, UNDERGROUND
MATERIAL: 10 GA CARBON STEEL
CONTINUOUS WELD INTERIOR AND EXTERIOR SEAMS
SURFACE PREP: SSPC-SP 10 BLAST ALL SURFACES
INT. & EXT. COATING: CHEMLINE 2240 - 15 MILS DFT

NOTES

STANDARD TANK MATERIAL IS COATED CARBON STEEL - STAINLESS STEEL CONSTRUCTION IS OPTIONAL

DRAWING SHOWS <u>STANDARD</u> TANK HEIGHT DIMENSION FROM INLET/DUTLET FITTINGS TO FINISHED FLOOR - <u>CUSTOMER MUST SPECIFY</u>
HEIGHT <u>DIMENSION MODIFICATIONS NEEDED TO MEET PROJECT PLUMBING REQUIREMENTS</u>

CUSTOMER APPROVAL

THE CUSTOMER HAS REVIEWED THIS DRAWING AND VERIFIED THE ACCURACY OF ALL INFORMATION AND DIMENSIONS.

SIGNED:

DATE:

NUITE:
ALL RIGHTS RESERVED. THIS DRAWING, DR ANY PART THEREOF, MUST NOT
BE REPRODUCED IN ANY FORM WITHOUT WRITTEN PERMISSION FROM
HIGHLAND TANK. UNLESS DITHERWISE NOITED, HIGHLAND TANK SHALL BE
RESPONSIBLE DNLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING.
THE CUSTOMER IS RESPONSIBLE FOR VERIFYING THE CORRECTNESS OF
THE TYPE, SIZE, AND LOCATION OF ALL FITTINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.



ELEVATOR OIL INTERCEPTOR

EOI-150

CUSTOMER:

PROJECT:

QUOTE NO.:

| Control | Co