


NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WITTEN PERMISSION OF HIGHLAND TANK®. HIGHLAND TANK® HIGHLAND TANK® SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTIVESS OF SIZE AND LOCATION OF FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.


TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.

SHIP LOOSE: (INSTALLATION ON SITE BY OTHERS) 1/2" BUTTON SIGHT GLASS









REFERENCE DRAWINGS

PRESS BRAKE - A19207 LEG DETAIL - WBLEG

_ 1/2"ø HOLES 	DESIGN DATA
	CAPACITY - 180 GALLONS
	TYPE - DOUBLE WALL - TYPE I
	NO. REQ
11."	OPERATING PRESSURE - ATMOSPHERIC
\$\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	SPECIFIC GRAVITY = 1.0
'8	TANK MATERIAL — MILD CARBON STEEL
	THICKNESS - ALL - 12 GAUGE
9 <mark>3</mark> "	CONSTRUCTION — LAP WELD OUTSIDE ON DOUBLE WALL SIDES A SINGLE WALL TOP
12"	TANK TEST — INNER — 2 PSIG OUTER — 2 PSIG AND FUL
2"	INT. FINISH — NONE
	EXT. FINISH - SHOP PRIMER
ATERIAL – 10 GAUGE CARBON STEEL	LABEL - UL 142 MAX TOP LOAD 60#

CAPACITY - 180 GALLONS
TYPE - DOUBLE WALL - TYPE I
NO. REQ
OPERATING PRESSURE - ATMOSPHERIC
SPECIFIC GRAVITY = 1.0
TANK MATERIAL - MILD CARBON STEEL
THICKNESS - ALL - 12 GAUGE
CONSTRUCTION — LAP WELD OUTSIDE ONLY DOUBLE WALL SIDES AND BOTTOM SINGLE WALL TOP
TANK TEST - INNER - 2 PSIG OUTER - 2 PSIG AND FULL VACUUM

]	Α	2" FITTING
	В	4" FITTING - PRIMARY EMERGENCY VENT USE
	С	4" FITTING MOUNTED IN INTERSTICE EXTENSION BOX — MARK WITH LABEL — SECONDARY EMERGENCY VENT USE ONLY
	D	1/2" FITTING THROUGH OUTER SHELL ONLY — WITH BUTTON SITE GLASS
	Ε	MOUNT PER DETAIL
	F	_

LEGEND

