PROVIDED EQUIPMENT GENERAL SPECIFICATIONS 1. 3"X3"X1/4" FLAT W/ 1/2" HOLE DRILLED IN CENTER NO. REQ'D: (1) CAPACITY: 200 GALLONS SPILL CAPACITY: 80 GALLONS (GROUNDING LUG) SEDIMENT CHAMBÉR 3. OIL WATER SEPARATOR CHAMBER TYPE: RECTANGULAR, HT, ABOVEGROUND, DOUBLEWALL 4. THREADED INLET MATERIAL: MILD CARBON STEEL (53)PVC INLET ELBOW PIPING APPROX. WEIGHT: 975 LBS. 6. VELOCITY HEAD DIFFUSION BAFFLE - 10GA FLOW RATE: 10 GPM 7. WEAR PLATE - 1/4' GAUGE: INNER: 8. REMOVABLE PARALLEL CORRUGATED PLATE COALESCER SHELL- 7 GA 10 GA (GALVANIZED PLATES) **HEADS-** 7 GA 10 GA SLUDGE BAFFLE - 10GA SURFACE PREP: 10. PVC OUTLET DOWNCOMER PIPE SSPC NO.10 BLAST ALL INTERIOR SURFACES 11. THREADED OUTLET SSPC NO.6 BLAST ALL EXTERIOR SURFACES 12. (4) PIECE COVER - 7 GA MATERIAL COATING: **THICKNESS** 13. NÚTS & BOLTS W/ LARGE WING NUTS-TYP. EXTERIOR - FINISH PAINT WHITE (3 MILS) (CORROSION RESISTANT) INTERIOR- POLYURETHANE (15 MILS) GASKET MATERIAL (FOR EACH REMOVABLE COVER) **CONSTRUCTION:** 15. 3"ø NPT (CLEAN-OUT) BUTT FIT & WELD ALL CORNERS IN & OUT 16. 2"ø NPT (FITTING FOR VENT) (21) (18)17. 2"Ø HALF COUPLING (DRAIN) W/ STEEL PLUG 18. 3"Ø FULL COUPLING W/ 3" Ø INTERNAL PVC PIPE (19) NOTES: 1. ALL INTERNAL MATERIAL IS 10 GA 19. 2"ø HALF COUPLING (FITTING FOR LEVEL SENSOR) 20. 2"ø 90 'ELBOW W/ 2" HALF COUPLING ON TOP 2. ALL FITTINGS MUST SHIP W/ STEEL 15" 16" 19" PLUGS INSTALLED WITH PVC RISER PIPE 3. LIFTING LUGS DO NOT HAVE REINFORCING REMOVABLE 'REMOVABLE' REMOVABLE REMOVABLE 21. 7 GA BRACING ACROSS TOP OF TANK W/ SENSOR COVER COVER COVER COVER **PLATES** & PUMP-OUT FITTINGS 22. LIFTING LUGS PLAN 23. 2"ø FERNCO COUPLING 24. 2" Ø COUPLING FOR LEAK DETECTION 26" (19) (24)25. HANDLES FROM 3/4"Ø ROUND PER H.T. STANDARD 26. 1" Ø COUPLING W/ PLUG (19)(18) (12) 12" (21) (13)(14)(14)(16) (15) **ACAP** (25)**এ**১৫৮ 12" (55) (53) (22)(6) (20) (10) 3" 6" 18" **REVISIONS** (17) 12" 9" A.C.A.P. 13" 14" TYP. (17) 200 GALLON OIL WATER SEPARATOR RECTANGULAR, HT. DOUBLE WALL END VIEW **CUSTOMER:** ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION PROJECT: OF HIGHLAND TANK. **ELEVATION** HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED CHK'D BY: ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER QUOTE NO: IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION

OF FITTINGS, ACCESSORIES & COATINGS SHOWN ON THIS DRAWING

SCALE: DATE:

00200 RHTDW

3/4"=1'-0"