
GENERAL SPECIFICATIONS NO. REQ'D: (1) CAPACITY: 200 GALLONS SPILL CAPACITY: 80 GALLONS TYPE: RECTANGULAR, HT, ABOVEGROUND, SINGLEWALL MATERIAL: MILD CARBON STEEL APPROX. WEIGHT: 900 LBS. FLOW RATE: 10 GPM **GAUGE:** SHELL- 7 GA **HEADS-** 7 GA SURFACE PREP: SSPC NO.10 BLAST ALL INTERIOR SURFACES SSPC NO.6 BLAST ALL EXTERIOR SURFACES MATERIAL COATING: **THICKNESS** EXTERIOR - FINISH PAINT WHITE (3 MILS) INTERIOR- POLYURETHANE (15 MILS) **CONSTRUCTION:** BUTT FIT & WELD ALL CORNERS IN & OUT


NOTES:

- 1. ALL INTERNAL MATERIAL IS 10 GA
- 2. ALL FITTINGS MUST SHIP W/ STEEL PLUGS INSTALLED
- 3. LIFTING LUGS DO NOT HAVE REINFORCING **PLATES**




ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK.

HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION OF FITTINGS, ACCESSORIES & COATINGS SHOWN ON THIS DRAWING



PLAN



ELEVATION

PROVIDED EQUIPMENT

- 1. 3"X3"X1/4" FLAT W/ 1/2"ø HOLE DRILLED IN CENTER (GROUNDING LUG)
- SEDIMENT CHAMBÉR
- 3. OIL WATER SEPARATOR CHAMBER
- 4. THREADED INLET
- 5. PVC INLET ELBOW PIPING
- 6. VELOCITY HEAD DIFFUSION BAFFLE 10GA
- 7. WEAR PLATE 1/4"
- 8. REMOVABLE PARALLEL CORRUGATED PLATE COALESCER (GALVANIZED PLATES) 1" PLATE SPACING 9. SLUDGE BAFFLE — 10GA
- 10. PVC OUTLET DOWNCOMER PIPE
- 11. THREADED OUTLET
- 12. (4) PIECE COVER 10 GA
- 13. NÚTS & BOLTS W/ LARGE WING NUTS-TYP. (CORROSION RESISTANT)
- GASKET MATERIAL (FOR ÉACH REMOVABLE COVER)
- 15. 3"ø NPT (CLEAN-OUT)
- 16. 2"ø NPT (FITTING FÓR VENT)
- 17. 2"Ø HALF COUPLING (DRAIN) W/ STEEL PLUG 18. 3"Ø FULL COUPLING W/ 3"Ø INTERNAL PVC PIPE
- 19. 2"ø HALF COUPLING (FITTING FOR LEVEL SENSOR)
- 20. 2"ø 90 ' ELBOW W/ 2" HALF COUPLING ON TOP WITH PVC RISER PIPE
- 21. 7 GA BRACING ACROSS TOP OF TANK W/ SENSOR & PUMP-OUT FITTINGS
- 22. LIFTING LUGS
- 23. 2"ø FERNCO COUPLING
- 24. HANDLES PER H.T. STANDARD 25. 1"Ø COUPLING W/ PLUG



CUSTOMER:

PROJECT:

QUOTE NO:

SCALE: DATE:

CHK'D BY:

3/4"=1'-0" 00200 RHTSW