



NOTES: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK®. HIGHLAND TANK® SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE AND LOCATION OF FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS
REQUIRED BY INSTALLATION
CONTRACTOR. TOUCH UP PAINT SHIPPED
WITH TANK.



<u>DESIGN DATA</u>	
CAPACITY	— 240 GALLONS
TYPE	— BDV2 SINGLE WALL VERTICAL
NO. REQ.	—
OPERATING PRESSURE	— ATMOSPHERIC
SPECIFIC GRAVITY	= 1.0
TANK MATERIAL	— MILD CARBON STEEL
THICKNESS — TOP:	12 GA
THICKNESS — BOTTOM:	12 GA
THICKNESS — SHELL:	12 GA
CONSTRUCTION	— LAP WELD OUTSIDE ONLY
TANK TEST	— 2 PSIG
INT. FINISH	— NONE
EXT. FINISH	— SHOP PRIMER
LABEL	— UL 142

<u>LEGEND</u>	
A	4" FNPT FITTING (PRIMARY VENT USE)
B	2" FNPT FITTING
C	3/4" FNPT FITTING
D	—
E	—
F	—

<u>NOTES</u>	
1.	SEE PLAN VIEW FOR TRUE ORIENTATION AND LOCATION OF FITTING
2.	LIFTING LUGS FOR UNLOADING UNIT & STANDING UNIT UPRIGHT TO BE PLACED AS NEEDED BY FABRICATION SHOP

					
		Highland Tank			
UNLESS NOTED, TOLERANCES ARE +/- 1"					
240 GAL 38"Ø BDV2 SW VERT. TANK					
CUSTOMER:					
PROJECT:					
QUOTE NO:				CHK'D BY:	
SCALE:	DATE:	DWG. BY:	DWG. NO.:		