

	<u>GENERAL SPECIFICATIONS</u>
	QUANTITY: ONE (1)
	MODEL: MOI-250 SO
	MAXIMUM FLOW RATE: 250 GPM
	STATIC CAPACITY: 359 GALLONS
	OIL STORAGE CAPACITY: 280 GALLONS
	TYPE: SINGLE WALL, UNDERGROUND
	MATERIAL: 10 GA CARBON STEEL
	CONTINUOUS WELD INTERIOR AND EXTERIOR SEAMS
	SURFACE PREP: SSPC-SP 10 BLAST ALL SURFACES
	INT. & EXT. COATING: CHEMLINE 2240 – 15 MILS DFT
	NOTES
	STANDARD TANK MATERIAL IS COATED CARBON STEEL –
	STAINLESS STEEL CONSTRUCTION IS OPTIONAL
	DRAWING SHOWS STANDARD TANK HEIGHT DIMENSION FROM
	INLET/OUTLET FITTINGS TO FINISHED FLOOR - <u>CUSTOMER</u>
	MUST SPECIFY HEIGHT DIMENSION MODIFICATIONS REQUIRED TO
	MEET PROJECT PLUMBING CONDITIONS
	STANDARD TANK LID IS RATED FOR PEDESTRIANS ONLY – H–20 TRAFFIC RATED LIDS ARE OPTIONAL
	H-ZU TRAFFIC RATED LIDS ARE UPTIONAL
	CUSTOMER APPROVAL
NPT VENT	
	THE CUSTOMER HAS REVIEWED THIS
<u>+</u>	
└─6″ Ĭ	DRAWING AND VERIFIED THE ACCURACY DF
	ALL INFORMATION AND DIMENSIONS.
↓ 14″ TD	
INVERT	SIGNED:
	SIGNED
V	
	DATE:
	│ N□TE: │ ALL RIGHTS RESERVED. THIS DRAWING, DR ANY PART THEREDF, MUST NDT
/	BE REPRODUCED IN ANY FORM WITHOUT WRITTEN PERMISSION FROM
	HIGHLAND TANK. UNLESS OTHERWISE NOTED, HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING.
	THE CUSTOMER IS RESPONSIBLE FOR VERIFYING THE CORRECTNESS OF THE TYPE, SIZE, AND LOCATION OF ALL FITTINGS, ACCESSORIES, AND
	CEATINGS SHEWN EN THIS DRAWING.
	MANUAL OIL INTERCEPTOR
	MOI-250 SO
	WUTZJU JU
	CUSTOMER:
	PROJECT:
	DRDER:
	QUOTE NO.: SCALE: DATE: DWG. BY: DWG. ND.:
DIMENSION TOLERANCE: ± 1"	