


NOTE:
ALL RIGHTS RESERVED, THIS DRAWING OR ANY PART THEREOF MUST NOT BE REPRODUCED IN ANY FORM W/O THE WRITTEN PERMISSION OF HIGHLAND TANK
HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION OF FITTINGS, ACCESSORIES & COATINGS SHOWN ON THIS DRAWING

120" X 1/4" STANDARD
FLANGED AND DISHED HEAD


- A 6" Ø NIPPLE [TOE] WITH EMERGENCY VENT
B 2" HCPLG [SUCTION]
C ----
D 2" HCPLG [NORMAL VENT]
E ----
F 2" MONITORING TUBE
G 4" HALF CPLG WITH 4 X 2 DOUBLE TAPPED BUSHING
WITH 2" CLOSE NIPPLE & 2" LOCKING FILL CAP
H 2" HCPLG [GAUGE]
J ----
K ----



CAP - 3000 GAL
MATERIAL - 7 GA MILD CARBON STEEL
TOP HEAD - 1/4" STANDARD FLG'D & DISHED
CONSTR - LAP WELD OUTSIDE ONLY
 [INNER TANK IS NOT ATTACHED TO OUTER TUB]
TEST - 5 PSIG INNER TANK ONLY
 OUTER TUB - WATER TIGHT
LABEL - UL 142 - APPLY LABEL ON TOP OF TANK
PAINT - TUB - SHOP PRIMER
 TANK - SHOP PRIMER
TANK SUPPORTS - 10 GA X 4" WIDE X 2"
 DEEP PRESS BROKE "U"

SHIP LOOSE

- [1] 2" Ø X 96" LONG
GALVANIZED PIPE [TBE]
- [1] 2" MUSHROOM VENT
- (1) 70" LONG GAUGE

1	CHANGED PAINT	01-10-00	009
 <h1>Highland Tank</h1>			
3000 GAL FUEL HOPPER			
CUSTOMER: NAME			
PROJECT: ?			
QUOTE NO: #			
SCALE 1/2" = 1' - 0"	DATE 09-20-99	DRAWN BY 009	CHK'D BY DWG NO FH3000