



GENERAL SPECIFICATIONS

NO. REQ'D: (1)
CAPACITY: 500 GALLON
TYPE: HYDRO RAINWATER COLLECTION, HIGHGUARD, SINGLE WALL
MATERIAL: MILD CARBON STEEL
GAUGE: 7 GA.
HEADS: 7 GA.
(BASED ON A 60" MAX. BURIAL DEPTH)
SURFACE PREP: SSFC NO.6 BLAST ALL EXTERIOR SURFACES
COATING: MATERIAL THICKNESS
EXTERIOR- POLYURETHANE (75 MILS)
INTERIOR- HIGHDRO-LINER PLUS
CONSTRUCTION : LAP FIT & WELD ALL EXTERIOR SEAMS
OPERATING PRESSURE : ATMOSPHERIC
NOTES:
1. POLYURETHANE HIGHGUARD TANK IS NOT APPROVED FOR THE STORAGE OF HEATED PRODUCTS
2. ALL VENT PIPING BY INSTALLER
3. 15000 VOLT SPARK TEST PROVIDED AT FACTORY
4. LIFTING LUGS PLACED AS NEEDED PER FAB SHOP




END VIEW

NOTE :
ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK.
HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION OF FITTINGS , ACCESSORIES & COATINGS SHOWN ON THIS DRAWING



PLAN



ELEVATION

PROVIDED EQUIPMENT

- 4"Ø PIPE STUB W/ 2" NPT FOR VENT (OVERFLOW SKIMMER)
- 2"Ø F.T.G. FOR VENT
- VELOCITY HEAD DIFFUSION BAFFLE (REMOVABLE)
- WEAR PLATE
- 4"Ø PIPE STUB (INLET)
- UNDERFLOW BAFFLE
- 2"Ø FULL CPLG. FOR PUMP MOUNTING
- STIRRED PLATES
- 4"Ø F.T.G. FOR GAUGE WITH PLUG
- 30" Ø MANWAY WITH BOLT-ON EXTENSION SHIPPED LOOSE
- 4"Ø F.T.G. FOR PUMP & LEVEL SENSOR CONDUIT
- 2"Ø F.T.G. W/ MOUNT FOR LEVEL SENSOR
- LIFTING LUG

REVISIONS



Highland Tank

U.S. Patent #4,700,880 Canadian Patent # 1,276,063
#4,886,204 # 2,397,265

500 HYDRO RAINWATER COLLECTION
HIGHGUARD, SINGLE WALL

CUSTOMER:

PROJECT:

QUOTE NO:

DATE: 10/16/10

DWG. BY:

DWG. NO.:

CHECK BY: