NOTE: FITTING SCHEDULE GENERAL NOTES ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST CAPACITY: 550 GALLONS NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION TYPE: SINGLE WALL, ABOVEGROUND, LIGHT DUTY SKID NO. REQ.: OF HIGHLAND TANK. B= 2" Ø NPT HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION C= 4" Ø NPT (EMERGENCY VENT) MATERIAL: MILD CARBON STEEL TEST: 5 P.S.I. OF FITTINGS, ACCESSORIES & COATINGS SHOWN ON THIS DRAWING MIN. GAUGE OR THICKNESS (PER U.L. 142): HEADS: 7 GA. SHELL: 7 GA. PAINT : INTERIOR : NONE EXTERIOR: RED PRIMER CONSTRUCTION: FLAT FLANGED HEADS, LAP WELD ALL EXTERIOR SEAMS ONLY APPROVED LABELS: U.L. 142 OPERATING PRESSURE— ATMOSPHERIC 15" 12" 12" ø48" C.L. TANK 6"x7GA. BELLY BAND (2) REQ'D. $6" \times 10" \times 7 \text{ GA}.$ 36" LONG FLAT (4) REQ. 6" TYP. 2" x 2" x 1/4" ANGLE PULL HOOK RUNNING WIDTH OF SKID 2" x 2" x 1/4" ANGLE RUNNERS (2) REQ. 6" x 10" x 7 GA. FLAT (4) REQ. 26" 26" 32" 2" 2" REVISIONS 36" **ELEVATION VIEW** END VIEW 550 GALLON ABOVEGROUND HORIZONTAL SINGLE WALL LIGHT DUTY SKID **CUSTOMER:** PROJECT: CHK'D BY: QUOTE NO: SCALE: DATE: 3/4"=1'-0" DWG. BY: