



DESIGN DATA
CAPACITY – 750 GALLONS
TYPE – DOUBLE WALL
NO. REQ. – –
OPERATING PRESSURE – ATMOSPHERIC
SPECIFIC GRAVITY = 1.0
TANK MATERIAL – MILD CARBON STEEL
THICKNESS INNER – 10 GAUGE THICKNESS OUTER – 10 GAUGE
CONSTRUCTION – INNER– LAP WELD OUTSIDE ONLY OUTER– LAP WELD OUTSIDE ONLY
TANK TEST – 2 PSIG –
INT. FINISH – NONE –
EXT. FINISH – SHOP PRIMER –
LABEL – UL 142

LEGEND	
A	2" FITTING
B	6" FITTING (PRIMARY EMERGENCY VENT USE)
C	6" FITTING IN INTERICE EXTENSION BOX – MARK WITH SPECIAL WARNING LABEL – INTERSTICE EMERGENCY VENT
D	1/2" FITTING THROUGH OUTER SHELL ONLY WITH BUTTON SITE GLASS
E	–
F	–

TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.

NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK®. HIGHLAND TANK® SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE AND LOCATION OF FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.

Highland Tank®

750 GAL UNDER CATWALK DW TANK

CUSTOMER:

PROJECT:

QUOTE NO:

CHK'D BY:

SCALE:	DATE:	DWG. BY:	DWG. NO.:
1/2" = 12"			00750UCDW