


NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®.
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTNESS OF SIZE AND
LOCATION OF FITTINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED







DESIGN DATA

CAPACITY - 1,000 GALLONS

TYPE - BDV1 SINGLE WALL

NO. REQ. - -

OPERATING PRESSURE - ATMOSPHERIC

SPECIFIC GRAVITY = 1.0

TANK MATERIAL - MILD CARBON STEEL

THICKNESS - TOP: 7 GA THICKNESS - BOTTOM: 7 GA THICKNESS - SHELL: 7 GA

CONSTRUCTION - LAP WELD OUTSIDE ONLY

TANK TEST - 2 PSIG

INT. FINISH - NONE

EXT. FINISH - SHOP PRIMER

LABEL - UL-142

LEGEND

l	Α	6" FFSO 150# FLANGE — PRIMARY EMERGENCY VENT USE
	В	2" FNPT FITTING
	С	3/4" FNPT FITTING
ı		


 $D \mid -$

Ε

F

NOTES

- 1. SEE PLAN VIEW FOR TRUE ORIENTATION AND LOCATION OF FITTING
- 2. LIFTING LUGS FOR UNLOADING UNIT & STANDING UNIT UPRIGHT TO BE PLACED AS NEEDED BY FABRICATION SHOP



PROJECT:

CHK'D BY: QUOTE NO: DWG. BY:

01000BDV1SW64 SCALE: DATE: 1/2"=1'-0"