





NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®.
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTNESS OF SIZE AND
LOCATION OF FITTINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS
REQUIRED BY INSTALLATION
CONTRACTOR. TOUCH UP PAINT SHIPPED
WITH TANK.

<u>DESIGN DATA</u>
CAPACITY –1000 GALLONS
TYPE – SINGLE WALL
NO. REQ. – –
OPERATING PRESSURE –ATMOSPHERIC
SPECIFIC GRAVITY = 1.0
TANK MATERIAL – MILD CARBON STEEL
THICKNESS – 10 GAUGE
CONSTRUCTION –LAP WELD OUTSIDE ONLY –
TANK TEST –2 PSIG –
INT. FINISH – NONE –
EXT. FINISH –SHOP PRIMER –
LABEL – UL 142

<u>LEGEND</u>	
A	2" FITTING
B	6" FFSO 150# FLANGE – EMERGENCY VENT USE
C	—
D	—
E	—
F	—



 Highland Tank	
UNLESS NOTED, TOLERANCES ARE $\pm 1"$ 1000 GAL SW LUBE TANK (S-STYLE)	
CUSTOMER:	
PROJECT:	
QUOTE NO: SCALE: $3/4" = 12"$	CHK'D BY: DWG. NO.: 01000LSWS
DATE:	DWG. BY: