


DTE: ALL RIGHTS RESERVED. THIS PAWING MUST NOT BE REPRODUCED IN FORM WITHOUT THE WRITTEN ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®.
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTNESS OF SIZE AND
LOCATION OF FITTINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING. COATINGS SHOWN ON THIS DRAWING.


DUCH UP OF FINISHED PAINT IS EQUIRED BY INSTALLATION CONTRACTOR, TOUCH UP PAINT SHIPPED WITH TANK.






| <u>DESIGN DATA</u> | |
|---|---|
| CAPACITY -1,000 GALLONS | |
| NO. REQ. — — | |
| OPERATING PRESSURE -ATMOSPHERIC | В |
| SPECIFIC GRAVITY = 1.0 | С |
| TANK MATERIAL — MILD CARBON STEEL THICKNESS — TOP: 7 GA FLANGED CONE OR STD. | D |
| FLANGED & DISHED THICKNESS — BALANCE OF TANK— 7 GA | Ε |
| CONSTRUCTION — TANK — LAP WELD OUTSIDE ONLY | |
| (INNER TANK IS NOT ATTACHED TO OUTER TUB) CONSTRUCTION— TUB — LAP WELD OUTSIDE ONLY | F |
| | |
| TANK TEST — TANK ONLY — 5 PSIG TUB TEST — TUB ONLY — WATERTIGHT | G |
| FINISH — TUB — INSIDE AND OUT — SHOP PRIMER FINISH — TANK — INTERIOR — NONE | Н |
| FINISH - TANK - EXTERIOR - SAME AS TUB | |
| LABEL — UL 142 — APPLY LABEL ON TOP OF TANK | J |
| TANK SUPPORT — 10 GA x 4" WIDE x 2" DEEP PRESSBRAKE "U" PATTERN | K |
| | |







SHIP LOOSE: (INSTALLATION BY OTHERS)

IN THE TANK SUPPORT.

- (1) GAUGE
- (1) 2"ø x 96" LONG GALVANIZED PIPE (T.B.E.)
- (1) 2"ø MUSHROOM VENT
- (1) 6" EMERGENCY VENT

