ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK.

HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION OF FITTINGS, ACCESSORIES & COATINGS SHOWN ON THIS DRAWING

## FITTING SCHEDULE

A= 4"ø NPT

B= 2"ø NPT C= 6"ø NPT (PRIMARY EMERGENCY VENT)

D= 6"ø NPT (SECONDARY EMERGENCY VENT)

E= 2"Ø NPT (LEAK DETECTION W/INTERNAL PIPE)

## GENERAL NOTES

CAPACITY: 1000 GALLONS

TYPE: DOUBLE WALL TYPE | 360°, ABOVEGROUND, LIGHT DUTY SKID

NO. REQ. :

MATERIAL: MILD CARBON STEEL

TEST: 5 P.S.I.

MIN. GAUGE OR THICKNESS (PER U.L. 142):

`OUTER HEADS': 10 GA. INNER HEADS: 10 GA. OUTER SHELL: 10 GA. INNER SHELL: 10 GA.

PAINT:

INTERIOR : NONE

EXTERIOR: RED PRIMER

CONSTRUCTION: FLAT FLANGED HEADS, LAP WELD ALL

EXTERIOR SEAMS ONLY

APPROVED LABELS: U.L. 142

OPERATING PRESSURE- ATMOSPHERIC

