NOTE: ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK. HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER

IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION

OF FITTINGS, ACCESSORIES & COATINGS SHOWN ON THIS DRAWING

END VIEW

FITTING SCHEDULE

A= 4" Ø NPT B= 2" Ø NPT

C= 6" Ø NPT (EMERGENCY VENT)

GENERAL NOTES

CAPACITY: 1,000 GALLONS

TYPE: SINGLE WALL, ABOVEGROUND, LIGHT DUTY SKID

NO. REQ. :

MATERIAL: MILD CARBON STEEL

TEST: 5 P.S.I.

MIN. GAUGE OR THICKNESS (PER U.L. 142): HEADS : 7 GA.

SHELL: 7 GA.


PAINT: INTERIOR: NONE

EXTERIOR: RED PRIMER

CONSTRUCTION: FLAT FLANGED HEADS, LAP WELD ALL

EXTERIOR SEAMS ONLY

APPROVED LABELS: U.L. 142 OPERATING PRESSURE— ATMOSPHERIC





1000 GALLON ABOVEGROUND HORIZONTAL SINGLE WALL LIGHT DUTY SKID

CUSTOMER:

PROJECT:

QUOTE NO:

CHK'D BY:

SCALE: DATE: 3/4"=1'-0"

01000SKLDSW7GA