



NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®.
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTNESS OF SIZE AND
LOCATION OF FITTINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.



DESIGN DATA
CAPACITY – 1,000 GALLONS
TYPE – SINGLE WALL, UNDERGROUND
NO. REQ. – –
OPERATING PRESSURE – ATMOSPHERIC
TANK MATERIAL –MILD CARBON STEEL
THICKNESS – HEADS: 10 GA
THICKNESS – SHELL: 10 GA
*GA THK. BASED ON 60” MAX. BURIAL DEPTH
CONSTRUCTION – LAP WELD OUTSIDE ONLY
–
TANK TEST – 5 PSIG
–
INT. FINISH – NONE
–
EXT. FINISH – BLACK COATING
–
LABEL – UL-58

LEGEND	
A	2” FITTING
B	–
C	–
D	–
E	–
F	–

SHOP TO INSTALL 1/4”x12”x12” STRIKER
PLATES, ROLLED AND SEAL WELD TO THE TANK

△					
		Highland Tank®			
1,000 GAL SW 48”Ø UNDERGROUND					
CUSTOMER:					
PROJECT:					
QUOTE NO:				CHK'D BY:	
SCALE:	DATE:	DWG. BY:	DWG. NO:		
3/4”=1'-0”			01000UGSW48GA10		

