



TOUCH UP OF FINISHED PAINT IS
REQUIRED BY INSTALLATION
CONTRACTOR. TOUCH UP PAINT SHIPPED
WITH TANK.



TANK INTERIOR MUST BE CLEAN, DRY, AND DEBRIS FREE

<u>LEGEND</u>	
A	2" FITTING w/ THREADED PLASTIC PLUG
B	4" FITTING w/ THREADED PLASTIC PLUG
C	6" FFSO 150# FLANGE w/ PLASTIC COVER – PRIMARY EMERGENCY VENT USE
D	1/2" FITTING WITH STEEL PLUG
E	3" x 3" PLATE w/ 1/2"ø (MIN.) HOLE ON CENTER (GROUNDING LUG–ONE REQ'D)
F	–

		<h1>Highland Tank</h1>	
UNLESS NOTED, TOLERANCES ARE +/- 1"			
1,500 GAL 64"Ø SW BDH LUBE TANK			
CUSTOMER:			
PROJECT:			
QUOTE NO:		CHK'D BY:	
SCALE: 1/2" = 12"	DATE:	DWG. BY:	DWG. NO.: 01500LBDHSW64