NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®.
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTNESS OF SIZE AND
LOCATION OF FIITINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR: TOUCH UP PAINT SHIPPED WITH TANK

<u>INSTALLED</u>


(1) HIGH-LINK LEVEL MODULE MODEL# LS-CS15-CAP 72" LONG & BUSHING.

SHIP LOOSE

DESIGN DATA

CAPACITY: 2,000 GALLONS

(2) 6" FLANGED EMERGENCY VENTS



ON NOTE . 2,000 ONEEDING			
TYPE: FIREGUARD® CYLINDRICAL			
FIREGUARD® IS A TRADEMARK OF THE STEEL TANK			
INSTITUTE			
NO. REQ. — —	<u>LEGEND</u>		
OPERATING PRESSURE — ATMOSPHERIC	A 4" SEVAN E SIDEONADO CONDUNO		.,,
SPECIFIC GRAVITY = 1.0	A 4" FEMALE FIREGUARD COUPLING	Н	6" SCH 40 PIPE
TANK MATERIAL — MILD CARBON STEEL	B 2" FEMALE FIREGUARD COUPLING		4" FEMALE FIREGUARD COUPLING
THICKNESS — INNER — HEADS AND SHELL — 7 GAUGE	B E TERMINE TRACESTAND SSSTERIO		T TEMPLE THEOGRAD COOTENCE
THICKNESS — OUTER — HEADS AND SHELL — 7 GAUGE	C 6" FFSO 150# FLANGE - PRIMARY EMERGENCY	_K	2" FEMALE FIREGUARD COUPLING
MIN. GAUGE OR THICKNESS (PER U.L. 2085)	VENT USE ONLY	- 1	2 TEMPLE TIREGOVIRB GGGT EITG
CONSTRUCTION — INNER — LAP WELD OUTSIDE ONLY	6" FFSO 150# FLANGE THROUGH OUTER SHELL	,	_
CONSTRUCTION — OUTER — LAP WELD OUTSIDE ONLY	ONLY, MARK WITH SPECIAL WARNING LABEL	-	
TANK TEST – PER UL 2085	INTERSTITIAL EMERGENCY VENT USE ONLY		
INT. FINISH - NONF	2" FITTING THROUGH OUTER SHELL ONLY		
THE PROPERTY OF THE PROPERTY O	WITH CAST IRON PLUG— MFG USE ONLY		
EVT FINICH OD C DEACT FINICH DAINT WHITE	2" INTERSTITIAL MONITOR PIPE — MALE		
EXT. FINISH — SP—6 BLAST, FINISH PAINT WHITE	NPT END		
	C 26" LONG x 14" WIDE x 4" HIGH CLOSED TOP		
LABEL— UL 2085 AND FIREGUARD® PER sti	STEEL ENCLOSURE WELDED TO OUTER TANK		



NOTES:

STRIKER PLATES ARE NOT SUPPLIED ON FIREGUARDS UNLESS SPECIFIED

