NOTE:
ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST
NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION
OF HIGHLAND TANK.

HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION OF FITTINGS. ACCESSORIES & COATINGS SHOWN ON THIS DRAWING

FITTING SCHEDULE

 $A = 4 \emptyset NPI$ $B = 2 \emptyset NPT$

C= 6" Ø NPT (PRIMARY EMERGENCY VENT)

D= 6" Ø NPT (SECONDARY EMERGENCY VENT)

E= 2" Ø NPT (FTG. FOR LEAK DETECTION)

GENERAL NOTES

CAPACITY: 2000 GALLONS

TYPE: I 360 DOUBLE WALL, ABOVEGROUND, HEAVY DUTY SKID

NO. REQ. : (1)

MATERIAL : MILD CARBON STEEL

TEST: 5 P.S.I.

MIN. GAUGE OR THICKNESS (PER U.L. 142):
INNER HEADS: 7 GA. OUTER HEADS: 10 GA.
INNER SHELL: 7 GA. OUTER SHELL: 10 GA.

PAINT : INTERIOR : NONE

EXTERIOR : RED PRIMER

CONSTRUCTION: FLAT FLANGED HEADS, LAP WELD ALL

EXTERIOR SEAMS ONLY

APPROVED LABELS: U.L. 142

OPERATING PRESSURE ATMOSPHERIC:

