


NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK®. HIGHLAND TANK® SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE AND LOCATION OF FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.



DESIGN DATA

CAPACITY — 2,500 GALLONS
TYPE — BDV1 SINGLE WALL
NO. REQ. — —
OPERATING PRESSURE — ATMOSPHERIC
SPECIFIC GRAVITY = 1.0
TANK MATERIAL — MILD CARBON STEEL
THICKNESS — TOP: 7 GA
THICKNESS — BOTTOM: 7 GA
THICKNESS — SHELL: 7 GA
CONSTRUCTION — LAP WELD OUTSIDE ONLY
TANK TEST — 2 PSIG
INT. FINISH — NONE
EXT. FINISH — SHOP PRIMER
LABEL — UL-142

LEGEND

A	6" FFSO 150# FLANGE — PRIMARY EMERGENCY VENT
B	2" FNPT FITTING
C	3/4" FNPT FITTING
D	24"Ø TIGHT BOLT MANWAY w/ 1/8" FIBREFLEX GASKET MATERIAL.
E	—
F	—

NOTES

- SEE PLAN VIEW FOR TRUE ORIENTATION AND LOCATION OF FITTING
- LIFTING LUGS FOR UNLOADING UNIT & STANDING UNIT UPRIGHT TO BE PLACED AS NEEDED BY FABRICATION SHOP

△					
		Highland Tank			
UNLESS NOTED, TOLERANCES ARE +/- 1"					
2,500 GAL 72"Ø BDV1 SW VERT. TANK					
CUSTOMER:					
PROJECT:					
QUOTE NO:				CHK'D BY:	
SCALE: 1/2"=1'-0"	DATE:	DWG. BY:	DWG. NO.: 02500BDV1SW72		