NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®.
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTNESS OF SIZE AND
LOCATION OF FIITINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.

SHIPPING LUGS AS NEEDED


SHIP LOOSE

(2) 6" FLANGED EMERGENCY VENTS

INSTALLED

(1) HIGH-LINK LEVEL MODULE MODEL# LS_XEXD 108" LONG & BUSHING.





CAPACITY: 4,000 GALLONS				
TYPE: FIREGUARD® CYLINDRICAL				
FIREGUARD® IS A TRADEMARK OF THE STEEL TANK INSTITUTE				
NO. REQ. — —				
OPERATING PRESSURE — ATMOSPHERIC				
SPECIFIC GRAVITY = 1.0				
TANK MATERIAL – MILD CARBON STEEL				
THICKNESS - INNER - HEADS-5/16" SHELL-1/4"				
THICKNESS — OUTER — HEADS— 5/16" SHELL—1/4" MIN. GAUGE OR THICKNESS (PER U.L. 2085)				
CONSTRUCTION — INNER — LAP WELD OUTSIDE ONLY				
CONSTRUCTION — OUTER — LAP WELD OUTSIDE ONLY				
TANK TEST — PER UL 2085				
INT. FINISH — NONE				
EXT. FINISH - SP-6 BLAST, FINISH PAINT WHITE				

LABEL- UL 2085 AND FIREGUARD® PER sti

DESIGN DATA

4	<u>LEGEND</u>				
	Α	4" FEMALE FG COUPLING	G	31" LONG x 14" WIDE x 4" HIGH CLOSED TOP STEEL ENCLOSURE WELDED TO OUTER TANK	
_	В	8" FFSO 150# FLANGE — PRIMARY EMERGENCY VENT USE ONLY	Ι	8" SCH 40 PIPE	
4" Y	С	8" FFSO 150# FLANGE THROUGH OUTER SHELL ONLY, MARK WITH SPECIAL WARNING LABEL	J	6" FEMALE FIREGUARD COUPLING	
		INTERSTITIAL EMERGENCY VENT USE ONLY	_ к	2" FEMALE FIREGUARD COUPLING	
Υ_	D	2" FITTING THROUGH OUTER SHELL ONLY WITH CAST IRON PLUG- MFG USE ONLY		_	
	Ε	2" MONITOR PIPE WITH MALE NPT END	L		
	F	24" x 1/4" PLATE TIGHT BOLT MANWAY WITH 1/8" THICK NEO-CORK GASKET			

NOTES:

STRIKER PLATES ARE NOT SUPPLIED ON FIREGUARDS UNLESS SPECIFIED

Highland Tank

UNLESS NOTED, TOLERANCES ARE +/- 1'

4,000 GAL 96" CYL. FIREGUARD OP®

PATENT: 5,695,089 PATENT: 5,809,650

CUSTOMER:

PROJECT:

QUOTE NO:
SCALE: DATE: DWG. BY: 4000FGCYL960P