

TOUCH UP OF FINISHED PAINT IS
REQUIRED BY INSTALLATION
CONTRACTOR. TOUCH UP PAINT SHIPPED
WITH TANK.

TOUCH UP OF FINISHED PAINT IS
REQUIRED BY INSTALLATION
CONTRACTOR. TOUCH UP PAINT SHIPPED
WITH TANK.



DESIGN DATA
CAPACITY – 4,000 GALLONS
TYPE – SINGLE WALL
NO. REQ. – –
OPERATING PRESSURE – ATMOSPHERIC
SPECIFIC GRAVITY = 1.0
TANK MATERIAL – MILD CARBON STEEL
THICKNESS – HEADS: 7 GA
THICKNESS – SHELL: 7 GA
CONSTRUCTION – LAP WELD OUTSIDE ONLY –
TANK TEST – 5 PSIG –
INT. FINISH – NONE –
EXT. FINISH – SHOP PRIMER –
LABEL – UL 142

TYPE - SINGLE WALL

OPERATING PRESSURE – ATMOSPHERIC

TANK MATERIAL – MILD CARBON STEEL

THICKNESS - SHELL: 7 GA

TANK TEST - 5 PSIG

	—
--	---

TANK MATERIAL – MILD CARBON STEEL	
THICKNESS – HEADS: 7 GA	
THICKNESS – SHELL: 7 GA	
CONSTRUCTION – LAP WELD OUTSIDE ONLY	
–	
TANK TEST – 5 PSIG	
–	
INT. FINISH – NONE	
–	
EXT. FINISH – SHOP PRIMER	
–	
LABEL – UL 142	

<u>LEGEND</u>	
A	6" FFSO 150# FLANGE – PRIMARY EMERGENCY VENT USE ONLY
B	4" FITTING
C	FB-3 X 1/4" X 3" WITH 5/8"Ø HOLE ON CL GROUNDING LUG
D	–
E	–
F	–

CONSTRUCTION – LAP WELD OUTSIDE ONLY	B	4" FITTING
--------------------------------------	---	------------

INT. FINISH - NONE	D -
--------------------	-----

—	F	—
LABE — III 142		

		Highland Tank	
UNLESS NOTED, TOLERANCES ARE +/- 1"			
4,000 GAL 64"Ø SW AG HORIZONTAL			
CUSTOMER:			
PROJECT:			
QUOTE NO:		CHK'D BY:	
SCALE: 1/2" = 12"	DATE:	DWG. BY:	DWG. NO: 04000AH SW 64