


TOUCH UP OF FINISHED PAINT IS
REQUIRED BY INSTALLATION
CONTRACTOR. TOUCH UP PAINT SHIPPED
WITH TANK.

A schematic diagram of a spherical tank. The tank is represented by a circle with a horizontal dashed line through its center. A vertical dashed line also passes through the center, extending to a small rectangular flange at the top. A diagonal line with arrows at both ends spans the diameter of the circle, labeled $\phi 5'-4''$. The tank is supported by two trapezoidal legs, one on the left and one on the right. The left leg is labeled 'C' and has a small square with a dot inside, representing a weld. Below the diagram, the text reads: 64" X 6" HIGH SUPPORTS WELDED TO TANK.



CAPACITY — 4,000 GALLONS
TYPE — SINGLE WALL
NO. REQ. — —
OPERATING PRESSURE — ATMOSPHERIC
SPECIFIC GRAVITY = 1.0
TANK MATERIAL — MILD CARBON STEEL
THICKNESS — HEADS: 7 GAUGE
THICKNESS — SHELL: 7 GAUGE
CONSTRUCTION — LAP WELD OUTSIDE ONLY
TANK TEST — 5 PSIG
INT. FINISH — NONE
EXT. FINISH — SHOP PRIMER
LABEL — UL 142

A	6" 150# FFSSO FLANGE (PRIMARY EMERGENCY VENT USE)
B	4" FITTING
C	3" x 3" PLATE w/ 1/2"Ø (MIN.) HOLE ON CENTER (GROUNDING LUG—ONE REQ'D)
D	—
E	—
F	—

