


NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®,
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR TIEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTINES OF SIZE AND
LOCATION OF FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.

GRADE LEVEL MANWAY NOT SHOWN THIS VIEW



- NULES:
 1) THE HIGHGUARD TANK IS NOT APPROVED FOR THE STORAGE OF HEATED PRODUCTS.
 2) 15,000 VOLT SPARK TEST PROVIDED AT FACTORY.
 3) SHOP TO INSTALL 1/4"x12"x12" STRIKER PLATES, ROLLED AND SEAL WELD TO THE TANK.

| L | E١ | GE | ΞN | <u>ID</u> |
|---|----|----|----|-----------|
| | | | | |

| TYPE - SINGLE WALL, HIGHGUARD UNDERGROUND | | | | | | | |
|--|--|--|--|--|--|--|--|
| NO. REQ. — — | | | | | | | |
| OPERATING PRESSURE - ATMOSPHERIC | | | | | | | |
| TANK MATERIAL - MILD CARBON STEEL | | | | | | | |
| THICKNESS INNER - HEADS: 7 GA, SHELL: 7 GA THICKNESS OUTER - HEADS: 10 GA, SHELL: 10 GA | | | | | | | |
| *GA THK. BASED ON 60" MAX. BURIAL DEPTH | | | | | | | |
| CONSTRUCTION - FLAT FLANGED HEADS, LAP WELD | | | | | | | |

INSIDE & OUTSIDE TANK TEST - 5 PSIG

CAPACITY - 4,000 GALLONS

INT. FINISH - SP10 BLAST HighDRO®-LINER PLUS FOR NSF 61 APPLICATIONS

EXT. FINISH - SP6 BLAST, 75 MILS POLYURETHANE LABEL - UL-1746 PART IV, HIGHGUARD

| Α | HTM SPIN BRK'T — MFG USE ONLY — NOT TO BE USED FOR FIELD INSTALLATION | | RFSO FLANGE INSIDE AND OUTSIDE WITH STD. WEIGHT CARBON STEEL INTERNAL DROP PIPE TO WITHIN 6" OF | |
|---|--|---|---|--|
| В | RFSO 150# FLANGE INSIDE AND OUTSIDE W/ INTERNAL STD. WEIGHT DROP PIPE WITH NFPA 22 ANTI-VORTEX PLATE AND EXTERNAL STD. WEIGHT CARBON STEEL RISER PIPE WITH LOCKING CAP (SUCTION) | | TANK BOTTOM, MITER 45°, & EXTERNAL RISER PIPE STD. WEIGHT CARBON STEEL WITH STORZ SINGLE OR DOUBLE CONNECTION (FIRE DEPT. CONNECTION/ FILL) | |
| С | 24"ø TIGHT BOLT MANWAY w/ å" THK. EPDM GASKET | Н | 24"Ø TIGHT BOLT MANWAY W/ 1" THK. EPDM GASKET | |
| D | D 2" FNPT FITTING (MANWAY VENT USE) | | 2" FNPT FITTING (MANWAY VENT USE) | |
| Ε | 16" WIDE INTERNAL LADDER W/ 3/4" RUNGS ON 12" SPACING. | К | 36"Ø GRADE LEVEL MANWAY | |
| F | RFSO FLANGE w/ 24" LONG STD. WEIGHT INTERNAL PIPE & EXTERNAL FLANGED SPOOL STD WEIGHT RISER PIPE (VENT/ LEVEL INDICATOR ASSEMBLY) | | | |



UNLESS NOTED, TOLERANCES ARE +/- 1

HighDRO® WATER STORAGE TANK 4,000 GAL 64"Ø UNDERGROUND SINGLE-WALL HORIZONTAL FOR FIRE PROTECTION WITH VERTICAL SUCTION

CUSTOMER:

PROJECT:

QUOTE NO: SCALE: DATE: 3/8"=1'-0"

CHK'D BY: 04000HGSWHDFPTVS64