



NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK®. HIGHLAND TANK® SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE AND LOCATION OF FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.



STRIKER PLATES ROLLED & SEAL WELDED TO THE
TANK, 1/4" X 12" X 12" MIN.

<u>DESIGN DATA</u>
CAPACITY – 8,000 GALLONS
TYPE – DOUBLE WALL – 360° TYPE II
NO. REQ. – –
OPERATING PRESSURE – ATMOSPHERIC
TANK MATERIAL – MILD CARBON STEEL
THICKNESS – HEADS– 1/4"
THICKNESS – SHELL – 1/4"
*GA THK. BASED ON 60" MAX. BURIAL DEPTH
CONSTRUCTION – LAP WELD OUTSIDE ONLY –
TANK TEST – INNER: 5 PSIG OUTER: FULL VACUUM
INT. FINISH – NONE –
EXT. FINISH – GREEN TITAN® WRAP –
LABEL – UL-58/UL-1746 PART III

<u>LEGEND</u>	
A	4" CLOSE OFF FITTING
B	4" CLOSE OFF FITTING WITH REMOVABLE LIFT LUG
C	2" CLOSE OFF FITTING WITH INTERNAL INTERSTICE MONITOR PIPE
D	—
E	—
F	—



		Highland Tank	
UNLESS NOTED, TOLERANCES ARE $\pm$ 1"			
8,000 GAL 10' TITAN[®]			
PATENT: 5,915,586 PATENT: 6,119,887		PATENT: 6,022,435 PATENT: 6,062,977	
CUSTOMER:			
PROJECT:			
QUOTE NO:		CHK'D BY:	
SCALE: 3/8"=1'-0"	DATE:	DWG. BY:	DWG. NO: 08000TITAN120