GENERAL SPECIFICATIONS

NO. REQ'D: (1)

CAPACITY: 9000 GALLONS

SPILL CAPACITY: 2700 GALLONS
TYPE: RECTANGULAR, HT, ABOVEGROUND, SINGLE WALL

MATERIAL: MILD CARBON STEEL APPROX. WEIGHT: 17800 LBS. FLOW RATE: 900 GPM


GAUGE: 1/4" THROUGHOUT

SURFACE PREP: SSPC NO.10 BLAST ALL INTERIOR SURFACES SSPC NO.6 BLAST ALL EXTERIOR SURFACES

MATERIAL THICKNESS EXTERIOR - FINISH PAINT WHITE (3 MILS) (15 MILS) INTERIOR - POLYURETHANE

BUTT FIT AND WELD ALL CORNERS IN & OUT


- 1. ALL INTERNAL MATERIAL IS 10 GA.
- 2. ALL FITTINGS MUST SHIP W/ STEEL PLUGS INSTALLED
- 3. LIFTING LUGS DO NOT HAVE REINFORCING **PLATES**



PLAN VIEW

PROVIDED EQUIPMENT


- 1. 3"X3"X1/4" FLAT W/ 1/2" HOLE DRILLED IN CENTER (GROUNDING LUG)
- SEDIMENT CHAMBÉR
- OIL WATER SEPARATOR CHAMBER
- 4. THREADED INLET
- PVC INLET ELBOW PIPING
- 6. VELOCITY HEAD DIFFUSION BAFFLE 10GA
- 7. WEAR PLATE (1/4" MATERIAL)
- 8. REMOVABLE PARALLEL CORRUGATED PLATE COALESCER (GALVANIZED) 1" PLATE SPACING
- 9. SLUDGE BAFFLE 10GA
- 10. PVC OUTLET DOWNCOMER
- 11. THREADED OUTLET
- 12. REMOVABLE COVERS 6-REQUIRED (7 GA.)
- 13. NUTS & BOLTS W/ LARGE WING (CORROSION RESISTANT)
 14. GASKET MATERIAL (FOR EACH REMOVABLE COVER)
- 15. 3"ø NPT (CLEAN-OUT)
- 16. 2"ø NPT (VENT)
- 17. 2"ø NPT (DRAIŃ)
- 18. 3"ø FULL COUPLING W/ 3" INTERNAL PVC PIPE
- 19. 2"ø NPT (FOR LEVEL SENSOR)
- 20. 7GA. CROSSMEMBER FOR OIL PUMP-OUT & LEVEL SENSOR FTG.
- 21. HANDLES PER H.T. STANDARDS
- 22. 1"ø COUPLING W/ PLUG
- 23. 12"ø STEEL ELBÓW W/ F.F. FLANGE WELDED TO TOP FOR PVC RISER PIPES
- 24. 12"ø ADJUSTABLE FERNCO COUPLING
- 25. LIFTING LUGS



END VIEW

ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK.

HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION OF FITTINGS, ACCESSORIES & COATINGS SHOWN ON THIS DRAWING



ELEVATION



RECTANGULAR, HT, SINGLE WALL

CUSTOMER:

PROJECT:

QUOTE NO:

CHK'D BY:

SCALE: DATE: |/4"=1'-0"

DWG. NO.: 09000 RHTSW