


## PROVIDED FOUIPMENT


- 1. 150# R.F.S.O. FLANGE W/ 2" NPT FOR VENT 2. 4"0 FTG. FOR GAUGE WITH PLUG TYP. BOTH MANWAYS
- 3. VELOCITY HEAD DIFFUSION BAFFLE
- 4. WEAR PLATE
- SEDIMENT CHAMBER
- 6. UNDERFLOW BAFFLE
- SLUDGE BAFFLE
- STRIKER PLATES 9. PARALLEL CORRUGATED PLATE COALESCER. CORELLA PVC PLATES
  10. OIL/WATER SEPARATOR CHAMBER
  11. 2"Ø FTG. FOR LEAK DETECTION

- 12. OUTLET DOWNCOMER
- 13. 24"Ø MANWAY WITH BOLT-ON EXTENSION SHIPPED LOOSE
- 14. 4"Ø FTG. FOR OIL PUMPOUT W/ INTERNAL PIPE INSTALLED & RISER PIPE SHIPPED LOOSE
- 15. 2"ø FTG. FOR LEVEL SENSOR W/ RISER PIPE SHIPPED LOOSE
- 16. LIFTING LUG
- 17. 2"ø FTG. FOR VENT TYP. BOTH MANWAYS



2. ALL VENT PIPING BY INSTALLER

3. 15000 VOLT SPARK TEST PROVIDED AT FACTORY



NOTE:
ALL RICHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST
NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION
OF HIGHLAND TANK. OF HIGHLAND TANK,
HIGHLAND TANK,
HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED
ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED, CUSTOMER
IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE / LOCATION
OF FITTINGS, ACCESSORIES & COATINGS SHOWN ON THIS DRAWING

**ELEVATION** 

