

NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®,
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERRYING CORRECTINESS OF SIZE AND
LOCATION OF FITTINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.





<u>DESIGN DATA</u>				
CAPACITY - 12,000 GALLONS				
TYPE - SINGLE WALL, HIGHGUARD UNDERGROUND				
NO. REQ. — —				
OPERATING PRESSURE – ATMOSPHERIC TANK MATERIAL – MILD CARBON STEEL				
*GA THK. BASED ON 60" MAX. BURIAL DEPTH				
CONSTRUCTION — FLAT FLANGED HEADS, LAP WELD INSIDE & OUTSIDE				
TANK TEST — 5 PSIG INT. FINISH — SP10 BLAST HighDRO®—LINER PLUS FOR NSF 61 APPLICATIONS				
				EXT. FINISH - SP6 BLAST, 75 MILS POLYURETHANE
LABEL — UL—1746 PART IV, HIGHGUARD				

STRIKER

PLATE

1) THE HIGHGUARD TANK IS NOT APPROVED FOR THE

32'-0"

- TO THE HIGH BOARD LAWN IS NOT APPROVED FOR THE STORAGE OF HEATED PRODUCTS.

 2) 15,000 VOLT SPARK TEST PROVIDED AT FACTORY.

 3) SHOP TO INSTALL 1/4"x12"x12" STRIKER PLATES, ROLLED AND SEAL WELD TO THE TANK.

		LEGEND		2" FNPT FITTING W/ 2" SCH 40 RISER PIPE (FOR LEVEL SENSOR)
-	Α	HTM SPIN BRK'T — MFG USE ONLY — NOT TO BE USED FOR FIELD INSTALLATION	G	FNPT FITTING W/ GOOSENECK VENT (VENT CONNECTION)
	В	FILL CONNECTION — RFSO 150# FLANGE w/ STD. WEIGHT RISER PIPE & INTERNAL DROP PIPE TO WITH	Н	24"ø TIGHT BOLT MANWAY w/ å" THK. EPDM GASKET MATERIAL & MANWAY EXTENSION
		IN 6" OF TANK BOTTOM, MITER END 45" (FILL)	J	2" FNPT FITTING (MANWAY VENT)
	С	24"Ø TIGHT BOLT MANWAY W/ 🖁 THK. EPDM GASKET MATERIAL & MANWAY EXTENSION	K	6" RFSO 150# FLANGE w/ ANTI-VORTEX PLATE PER NFPA 22 (SUCTION)
	D	2" FNPT FITTING (MANWAY VENT)	L	36"Ø GRADE LEVEL MANWAY
$\frac{1}{2}$	E	16" WIDE STAINLESS STEEL INTERNAL LADDER w/ \(\frac{1}{4} \)" RUNGS ON 12" SPACING	М	12"Ø GRADE LEVEL MANWAY

STRIKER-

PLATE ANTI-VORTEX PLATE-

