NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WRITTEN
PERMISSION OF HIGHLAND TANK®.
HIGHLAND TANK® SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTNESS OF SIZE AND
LOCATION OF FIITINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.

SHIPPING LUGS AS NEEDED


SHIP LOOSE

(2) 10" FLANGED EMERGENCY VENTS

INSTALLED

(1) HIGH-LINK LEVEL MODULE MODEL# LS_XEXD 135" LONG & BUSHING.





CAPACITY: 20,000 GALLONS					
TYPE: FIREGUARD® CYLINDRICAL					
FIREGUARD® IS A TRADEMARK OF THE STEEL TANK					
INSTITUTE					
NO. REQ. — —					
OPERATING PRESSURE - ATMOSPHERIC					
SPECIFIC GRAVITY = 1.0					
TANK MATERIAL — MILD CARBON STEEL					
THICKNESS - INNER - HEADS: 5/16", SHELL: 1/4"					
THICKNESS - OUTER - HEADS: 5/16", SHELL: 1/4"					
MIN. GAUGE OR THICKNESS (PER U.L. 2085)					
CONSTRUCTION — INNER — LAP WELD OUTSIDE ONLY					
CONSTRUCTION — OUTER — LAP WELD OUTSIDE ONLY					
TANK TEST - PER UL 2085					
INT. FINISH - NONE					
EXT. FINISH - SP-6 BLAST, FINISH PAINT WHITE					

LABEL- UL 2085 AND FIREGUARD® PER sti

DESIGN DATA

BASE PLATE DETAIL

STRIKER PLATES ARE NOT SUPPLIED ON FIREGUARDS® UNLESS SPECIFIED

	<u>LEGEND</u>				
	Α	4" FEMALE FIREGUARD COUPLING	G	33" LONG x 14" WIDE x 4" HIGH CLOSED TOP STEEL ENCLOSURE WELDED TO OUTER TANK	
	В	10" FFSO 150# FLANGE — FOR PRIMARY EMERGENCY VENT USE ONLY	Н	8" FEMALE FIREGUARD COUPLING	
	C	10" FFSO 150# FLANGE THROUGH OUTER SHELL ONLY, MARK WITH SPECIAL WARNING LABEL INTERSTITIAL EMERGENCY VENT USE ONLY	J	10" SCH 40 PIPE	
		Z" FITTING THROUGH OUTER SHELL ONLY WITH CAST IRON PLUG- MFG USE ONLY	K	2" FEMALE FIREGUARD COUPLING	
	E	2" INTERSTITIAL MONITOR PIPE - MALE NPT END	L	_	
	F	24" x 1/4" PLATE TIGHT BOLT MANWAY WITH 1/8" THICK NEO-CORK GASKET			

