

GENERAL SPECIFICATIONS

QUANTITY: ONE (1)

MODEL: PGI-20000 FL

STATIC CAPACITY: 20,000 GALLONS

TYPE: SINGLE WALL, HIGHGUARD, UNDERGROUND

MATERIAL: 3/8" CARBON STEEL

MATERIAL BASED ON 120" MAXIMUM BURIAL DEPTH LAP FIT AND WELD INTERIOR AND EXTERIOR SEAMS

TANK TEST: 3-5 PSI AIR TEST

SURFACE PREP: SSPC-SP 10 BLAST INTERIOR SURFACES SSPC-SP 6 BLAST EXTERIOR SURFACES

EXT. COATING: HIGHGUARD POLYURETHANE - 75 MILS INT. COATING: CHEMTHANE 4200 PW (15 MILS DFT)

OPERATING PRESSURE: ATMOSPHERIC

NOTE: OPTIONAL 2" VENTS ON MANWAY RISERS AT THE DISCRETION OF THE OWNER

PROVIDED EQUIPMENT

- 1. 8"ø SCH 40 PIPE STUB INLET
- 2. 8"ø SCH 40 PIPE STUB OUTLET
- 3. 2" HC FOR VENT
- 4. 24"ø MANWAY FOR STACKABLE RISER
- 5. STEEL OUTLET DOWNCOMER BAFFLE WITH OPEN TOP 18. (14) CDA-15 CONCRETE DEADMAN
- 6. STRIKER PLATE
- 7. 8"ø SCH 40 TRANSFER TEE
- 8. BOLT-ON INLET DIFFUSION BAFFLE 7 GA
- 9. 8"ø 45° DIFFUSION ELBOW
- 10. FULL BULKHEAD 3/8"
- 11. 2" OPENING FOR AIR CIRCULATION
- 12. 36"ø GRADE-LEVEL MANWAY SHIPPED LOOSE
- 13. 24"ø PVC COVER
- 14. (2) 24"ø x 12" STACKABLE RISER ALL STACKABLE RISER COMPONENTS ARE PRE-ASSEMBLED AND COMPLETE MANWAY RISER IS SHIPPED LOOSE

PROVIDED EQUIPMENT

(CONTINUED)

- 15. (2) 24"ø x 6" STACKABLE RISER
- 16. STACKABLE RISER ADAPTER RING & GASKET
- 17. STACKABLE RISER SAFETY SCREEN
- 19. (14) POLYESTER HOLD-DOWN STRAPS

THIS DRAWING IS SUBJECT TO CHANGE AT THE DISCRETION OF THE MANUFACTURER. CONTACT HIGHLAND TANK FOR THE MOST UP-TO-DATE INFORMATION AND DRAWINGS OF OUR PRODUCTS.

NUTLE:
ALL RIGHTS RESERVED. THIS DRAWING, OR ANY PART THEREOF, MUST NOT BE REPRODUCED IN ANY FORM WITHOUT WRITTEN PERMISSION FROM HIGHLAND TANK. UNLESS OTHERWISE NOTED, HIGHLAND TANK SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING. THE CUSTOMER IS RESPONSIBLE FOR VERIFYING THE CORRECTNESS OF THE TYPE, SIZE, AND LOCATION OF ALL FITTINGS, ACCESSORIES, AND COLATINGS SHOWN ON THIS DRAWING.



FLORIDA DEPARTMENT OF HEALTH APPROVAL NUMBER: 70-151-L200D16-C4

EFFECTIVE CAPACITY: 20,000 GALLONS

CUSTOMER:

ROJECT:

3/23/16 MGS

PGI-20000 FL

DIMENSION TOLERANCE: ± 1" QUOTE NO.: