


NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WITTEN
PERMISSION OF HIGHLAND TANK®,
HIGHLAND TANK®, SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTINESS OF SIZE AND
LOCATION OF FITTINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.

TOUCH UP DF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.







DESIGN DATA_	<u>LEGEND</u>
CAPACITY -30,000 GALLONS TYPE - FIRE PROTECTION TANK (FPT)	A FLANGE WITH INTERNAL ANTI-VORTEX PLATE PER NFPA 22
NO. REQ. –	B FLANGE - VENT
OPERATING PRESSURE — ATMOSPHERIC TANK MATERIAL — MILD CARBON STEEL	C 24" X 4" PLATE TIGHT BOLT MANWAY WITH 8" THICK NEO-CORK GASKET
THICKNESS: HEADS - 5/16" THICKNESS: SHELL - 1/4"	D 4" FNPT CONNECTION
CONSTRUCTION -LAP WELD INSIDE & OUTSIDE	STD HTM EXTERNAL LADDER & PLATFORM ASSEMBLY — PAINTED SAFETY YELLOW AND SHIPPED LOOSE FOR INSTALLATION ON SITE BY OTHERS
TANK TEST —5 PSIG INT. FINISH — SSPC SP10 BLAST, HighDRO®—LINER PLUS FOR NEPA 22 APPLICATIONS	F HTM STD INTERNAL LADDER
EXT. FINISH - SSPC SP6 BLAST, WHITE URETHANE PAINT	G FLANGE WITH INTERNAL 90' ELBOW SHOWN - OVERFLOW
LABEL - NONE	H FB-3"x 1/4"x3" WITH 5/8"Ø HOLE ON CL (GROUNDING LUG)

