


NOTE: ALL RIGHTS RESERVED. THIS
DRAWING MUST NOT BE REPRODUCED IN
ANY FORM WITHOUT THE WITTEN
PERMISSION OF HIGHLAND TANK®,
HIGHLAND TANK®, SHALL BE RESPONSIBLE
ONLY FOR ITEMS INDICATED ON THIS
FABRICATION DRAWING UNLESS OTHERWISE
NOTED. CUSTOMER IS RESPONSIBLE FOR
VERIFYING CORRECTINESS OF SIZE AND
LOCATION OF FITTINGS, ACCESSORIES, AND
COATINGS SHOWN ON THIS DRAWING.

TOUCH UP DF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.







DESIGN DATA_	<u>LEGEND</u>
CAPACITY -30,000 GALLONS	A FLANGE - SUPPLY
TYPE - POTABLE WATER TANK (PWT) NO. REQ	B FLANGE - VENT
OPERATING PRESSURE —ATMOSPHERIC TANK MATERIAL — MILD CARBON STEEL	C 24" X 1 PLATE TIGHT BOLT MANWAY WITH 1 THICK NEO-CORK GASKET
THICKNESS: HEADS - 5/16" THICKNESS: SHELL - 1/4"	D 4" FNPT CONNECTION
CONSTRUCTION -LAP WELD INSIDE & OUTSIDE TANK TEST -5 PSIG	STD HTM EXTERNAL LADDER & PLATFORM ASSEMBLY — PAINTED SAFETY YELLOW AND SHIPPED LOOSE FOR INSTALLATION ON SITE BY OTHERS
NT. FINISH — SP10 BLAST HighDRO®—LINER PLUS FOR NSF 61 APPLICATIONS	F HTM STD INTERNAL LADDER
EXT. FINISH -SSPC SP6 BLAST, WHITE URETHANE	G FLANGE WITH INTERNAL 90° ELBOW SHOWN — OVERFLOW
PAINT LABEL – NONE	H FB-3"x 1/4"x3" WITH 5/8"Ø HOLE ON CL (GROUNDING LUG)

