

TANK MATERIAL - MILD CARBON STEEL

*GA THK. BASED ON 60" MAX. BURIAL DEPTH

INT. FINISH - SP10 BLAST HighDRO®-LINER

LABEL - UL-1746 PART IV, HIGHGUARD

CONSTRUCTION - FLAT FLANGED HEADS, LAP WELD

EXT. FINISH - SP6 BLAST, 75 MILS POLYURETHANE

INSIDE & OUTSIDE

PLUS FOR NSF 61 APPLICATIONS


THICKNESS - HEADS- 1/4"

THICKNESS - SHELL- 3/8"

TANK TEST - 5 PSIG

NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGHLAND TANK®. SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE AND LOCATIONS SHOWN ON THIS DRAWING.

GRADE LEVEL MANWAY NOT SHOWN THIS VIEW



	<u>LEGEND</u>	F	2 FNP1 FITTING W/ 2 SCH 40 RISER PIPE (FOR LEVEL SENSOR)
Δ	USED FOR FIELD INSTALLATION	G	FNPT FITTING w/ GOOSENECK VENT (VENT CONNECTION)
E	WEIGHT RISER PIPE & INTERNAL DROP PIPE TO WITH	Н	24"Ø TIGHT BOLT MANWAY W/ 🖁 THK. EPDM GASKET MATERIAL & MANWAY EXTENSION
	IN 6" OF TANK BOTTOM, MITER END 45" (FILL)	J	2" FNPT FITTING (MANWAY VENT)
С	24"Ø TIGHT BOLT MANWAY W/ 8" THK. EPDM GASKET MATERIAL & MANWAY EXTENSION	K	6" RFSO 150# FLANGE w/ ANTI-VORTEX PLATE PER NFPA 22 (SUCTION)
	2" FNPT FITTING (MANWAY VENT)	L	36"Ø GRADE LEVEL MANWAY
Е	16" WIDE STAINLESS STEEL INTERNAL LADDER W/ 3" RUNGS ON 12" SPACING	М	12"Ø GRADE LEVEL MANWAY

Highland Tank

UNLESS NOTED, TOLERANCES ARE +/- 1"

HighDRO® WATER STORAGE TANK

30,000 GAL 126"Ø SINGLE-WALL UNDERGROUND HORIZONTAL FOR FIRE PROTECTION WITH BOTTOM DRAIN

CUSTOMER:

PROJECT:

1/4"=1'-0"

QUOTE NO:

CHK'D BY:

30000HGSWHDFPTBD126