## NOTES: PROVIDED FOUIPMENT GENERAL SPECIFICATIONS 1. POLYURETHANE HIGHGUARD TANK IS NOT APPROVED 1. 150# R.F.S.O. FLANGE W/ 2" NPT FOR VENT 2. 7 GA. BULKHEAD 3. VELOCITY HEAD DIFFUSION BAFFLE FOR THE STORAGE OF HEATED PRODUCTS NO. REQ'D: (1) 2. ALL VENT PIPING BY INSTALLER CAPACITY: 30,000 GALLONS TYPE: HT, HIGHGUARD, SINGLE WALL, "G" SERIES MATERIAL: MILD CARBON STEEL 3. 15000 VOLT SPARK TEST PROVIDED AT FACTORY 4. WEAR PLATE FLOW RATE: 3.000 GPM 5. SEDIMENT CHAMBER 6. UNDERFLOW BAFFLE GAUGE: 7. SLUDGE BAFFLE SHELL- 3/8" 8. STRIKER PLATES HEADS- 1/4" 9. PARALLEL CORRUGATED PLATE COALESCER 10. OIL/WATER SEPARATOR CHAMBER SURFACE PREP: 11. SLUDGE CHAMBER 12. OUTLET DOWNCOMER SSPC NO.6 BLAST ALL EXTERIOR SURFACES COATING: MATERIAL THICKNESS 13. 24"Ø MANWAY WITH BOLT-ON EXTENSION SHIPPED LOOSE EXTERIOR-HIGHGUARD (75 MILS) 14. 4"ø FTG. FOR OIL PUMP-OUT W/ INTERNAL PIPE INSTALLED INTERIOR-AND RISER PIPE SHIPPED LOOSE NONE 15. 2" o FTG. FOR LEVEL SENSOR W/ RISER PIPE SHIPPED LOOSE 16. LIFTING LUG CONSTRUCTION: LAP FIT & WELD ALL EXTERIOR (18) SEAMS (13) (13)17. 2"Ø FTG. FOR VENT TYP. BOTH MANWAYS (18) (18)**OPERATING PRESSURE: ATMOSPHERIC** 18. 4"Ø FTG. FOR GAUGE WITH PLUG TYP. BOTH MANWAYS (16) PLAN "ø 4" 38" 28" (9) ø126 51 18" (11) REVISIONS 10" 60 (10) (8) (8) (8) (2 (3) 10'

167"

57"

40"

37"

20"

- 9'-6"

30"

END VIEW

60"

48"

18"

123'

72"

— 56'-0" –

**ELEVATION** 

46'-6"

30000 GALLON OIL WATER SEPARATOR

HT, HIGHGUARD, SINGLE WALL, "G" SERIES

CHK'D BY:

30000HGSWHTG

CUSTOMER:

PROJECT:

QUOTE NO:

SCALE: DATE: 1/8"=1'-0" 8-9-05