


3. 15000 VOLT SPARK TEST PROVIDED AT FACTORY

ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTIVESS OF SIZE / LOCATION OF FITTINGS , ACCESSORIES & COATINGS SHOWN ON THIS DRAWING

PROVIDED FOUIPMENT

- 1. 150# R.F.S.O. FLANGE W/ 2" NPT FOR VENT 2. 4"% FTG. FOR GAUGE WITH PLUG TYP. BOTH MANWAYS
- 3. VELOCITY HEAD DIFFUSION BAFFLE
- 4. WEAR PLATE
- 5. SEDIMENT CHAMBER
- 6. UNDERFLOW BAFFLE
- 7. SLUDGE BAFFLE
- 8. STRIKER PLATES
- 8. STRIKER PLAIES
 9. PARALLEL CORRUGATED PLATE COALESCER. CORELLA PVC PLATES
 10. OIL/WATER SEPARATOR CHAMBER
 11. 2"ø FTG. FOR LEAK DETECTION

- 12. OUTLET DOWNCOMER
- 13. 24"Ø MANWAY WITH BOLT-ON EXTENSION SHIPPED LOOSE
- 14. 476 FTG. FOR OIL PUMPOUT W/ INTERNAL PIPE INSTALLED & RISER PIPE SHIPPED LOOSE
- 15. 2"Ø FTG. FOR LEVEL SENSOR W/ RISER PIPE SHIPPED LOOSE
- 16. LIFTING LUG
- 17. 2"ø FTG, FOR VENT TYP, BOTH MANWAYS



REVISIONS 40000 GALLON OIL WATER SEPARATOR HT, HIGHGUARD, DOUBLE WALL CUSTOMER: PROJECT: CHK'D BY: QUOTE NO: SCALE: DATE: 1/8"=1'-0" 7-31-07 40000HGDWHTHDS